

Message

From: Pat Hunt [WaterSewerSupvr@badriver-nsn.gov]
Sent: 11/21/2013 1:44:31 PM
To: Colletti, John [colletti.john@epa.gov]
CC: Hoffmann, Shane (IHS/BEM) [Shane.Hoffmann@ihs.gov]
Subject: Before Discharge and WWTP new phos. #'s
Attachments: BH - DV phos 2013.jpg

John,

As you can see the phosphate level in the WWTP lagoon is now 6.22 from 2.5. Before adding 200 gallons of alum it was at 2.5 and is now 6.22 I cannot figure it out and we are out of weather to continue adding alum. Dean Maraldo and the EPA have us on a compliance schedule which I am forced to ask the Tribal Chairman to ask for an extension for various reasons including the inability to lower the WWTP lagoon.

Also included are the prior numbers from the BH and DV lagoons and need your input asap so we can get started lowering both lagoons.

Patrick Hunt
Bad River Utility